

## FORM VI

(Regulation 389)

### CERTIFICATE FOR USE OF A BOILER

NO: SADB1/BLR/CFN-324/15-16

Dated : 14/03/2016

GSC.NO : IS0990000037986

Dated : 10/03/2016

Reg. No. of Boiler : MYS-1892

Type of Boiler : Package

Boiler Rating : 54.1 sq\_Mts

Place and year: Coimbatore 1993  
of manufacture

Maximum Continuous Evaporation : 1 TPH

Name of the Owner : M/s. Sri Maruthi Builders

Situation of Boiler : Railway Yard, MES Road, Yeshwanthpur  
560022

Repairs : NIL

Remarks : OI AND HT FOUND SATISFACTORY

Hydraulically Tested on 14/03/2016 to 15.0 Kg/Sq.cm(g)

I hereby certify that the above described boiler is permitted by me/  
under the provisions of Section 7/8 of the Indian Boiler Act, (No. V of 1923), to be worked  
at a maximum pressure of 10.54 Kg/Sq.Cm(g) for the period from  
14/03/2016 to 13/03/2017.

The loading of the 25.0 mm safety valve is not to exceed 10.54 Kg/Sq. Cm(g).

Fee Rs.2700 (Boiler)+150 (SteamLine) Paid on 10/03/2016 at SBM

Dated at

This day, 14th day of March ,2016

Senior Assistant Director of Boilers, Bangalore  
Division-1

Open up for cleaning after every 8 Weeks. See on the reverse for the conditions and keep record.

**CONDITIONS**  
**(Reverse of Form VI)**

- (1) No structural alteration, addition or renewal shall be made to the boiler otherwise than in accordance with section 12 of the Act.
- (2) Under the provisions of Section 8 of the Act this certificate shall cease to be in force:
- (a) on the expiry of the period for which it was granted; or
  - (b) when any accident occurs to the boiler; or
  - (c) when the boiler is moved the boiler not being vertical boiler the heating surface of which is less than eighteen point fifty eight square meters ( 18.58 Sq. Mts) , or a portable or vehicular boiler; or
  - (d) when any structural alteration, addition or renewal is made in or to the boiler; or
  - (e) if the Chief Inspector in any particular case so directs when any structural alteration, addition or renewal is made in or to any steam-pipe attached to the boiler; or
  - (f) on the communication to the owner of the boiler of an order of the Chief Inspector or Inspector prohibiting its use on the ground that it or any steam-pipe attached thereto is in a dangerous condition.

Under Section 10 of the Act, when the period of a certificate relating to a boiler has expired, the owner shall, provided that he has applied before the expiry of that period for a renewal of the Certificate, be entitled to use the boiler at the maximum pressure entered in the former certificate, pending the issue of orders on the application but this shall not be deemed to authorise the use of a boiler in any of the cases referred to in clause (b), (c), (d), (e) and (f) of sub-section (1) of section 8 occurring after the expiry of the period of the certificate.

- (3) The boiler shall not be used at a pressure greater than the pressure entered in the certificate as the maximum pressure nor with the safety valve set to a pressure exceeding such maximum pressure.
- (4) The boiler shall not be used otherwise than in a condition which the owner reasonably believes to be compatible with safe working.

NOTE.- The particulars and dimensions regarding this boiler may be obtained by the owner on payment in the prescribed manner on application to the Chief Inspector.